



LightWorks®

# Techno-economic Analysis of a High-Temperature Concentrated Solar Power Plant with a Multi-Level Storage System for a Year-Round Guaranteed Dispatchability

Ayse Parlak<sup>1</sup>, Alberto de la Calle<sup>2</sup>, Arindam Dasgupta<sup>1</sup>  
and Ellen B. Stechel<sup>2</sup>


<sup>1</sup>Siemens Corporation, Corporate Technology, USA

<sup>2</sup>ASU LightWorks®, Arizona State University, Tempe AZ, USA



# Introduction

Daggett CA




Although there are many technologies that cover **short-term** (daily) energy storage to stabilize the grid, only a few covers **medium-term** (weekly) and **long-term** (seasonal) energy storage and are not yet sufficiently developed

Weekly and seasonal storage provides a year-round guaranteed dispatchability



# CSP with multi-level storage system



This system offers a **unique flexibility**, where we can **buy and sell electricity** when it is most convenient and is allowed to **sell Hydrogen** as a commodity to offset the operational and capital costs


**Level 1 (Daily):** Sensible heat  
**Level 2 (Weekly):** Thermochemical heat  
**Level 3 (Seasonal):** Hydrogen





# System design: Next-generation CSP

Gen3 plant based: combines a free-falling particle receiver and a supercritical CO<sub>2</sub> power block








# System design: Thermochemical energy storage

L2 storage is based on a two-step redox-active metal oxide ( $MO_x$ ) thermochemical cycle

The TCES subsystem performs the thermal reduction of the  $MO_x$  in a low oxidation environment




The ER subsystem performs the re-oxidation of the  $MO_x$  with air, dispatching sensible and chemical energy to the  $sCO_2$  power block



# System design: Thermochemical energy storage

L3 storage produces and stores hydrogen with off-peak electricity

It is based on a two-step redox-active  $MO_x$  thermochemical cycle whose reactor is designed to work counter-current in both reactions at have an internal solid-solid heat recovery




Note that the L3 storage is not directly connected to the power cycle and uses the L2 as an intermediary



# System design: Thermochemical energy storage

Both, L2 and L3 storage systems, require inert gas for its operation


The O<sub>2</sub> removal subsystem purified this inert gas based on a two-step adsorption/desorption cycle









# System design: Full plant diagram








# System modeling: next generation CSP



System design


Annual performance



The simulation platform provides a method of quickly and accurately evaluating solar tower systems




# Results: next generation CSP



Best solution for each receiver configuration as function of solar multiple: LCOH and annual efficiency (Daggett CA)

## Design parameters

- Receiver configuration
- Receiver width (5-30 m step 1 m)
- Tower height (100-400 m step 5 m)



## Optimization

- Optimization algorithm: *surrogateopt*
- Objective function: cost-heat flow ratio


R3<sub>90</sub> exhibits the lowest LCOH for all the SMs assessed, LCOH ~\$11/MWh between SM: 1-3





# System modeling: multi-level energy storage

Tri-Level Storage Enabled Dispatchable CSP System Design Software



- User friendly simulation platform to simulate multi-level energy storage systems
- It is constructed using mixed-integer linear programming (MILP) formulation
- Includes constraints and objective functions
- Uses reduced order models and cost model of each of the subsystems

This tool can calculate the optimal system operation given a scenario to achieve the minimum levelized cost of energy



# Results: multi-level energy storage

LCOE (\$/MWh) for 100 MWe Nameplate

Level 1 Storage (MWh)	Solar Multiples										
	0.5	0.75	1	1.25	1.5	1.75	2	2.25	2.5	2.75	3
1500 (7.5 hrs)	189.8	137.5	104.8	93.4	80.2	73.9	70.0	68.9	71.7	75.0	77.6
1800 ( 9 hrs)	193.9	140.3	106.9	95.3	81.8	75.3	70.7	67.9	69.3	71.8	73.8
2000 ( 10 hrs)	190.8	137.9	105.0	93.9	81.2	75.2	71.0	67.7	68.3	70.1	71.8
2400 ( 12 hrs)	196.1	141.6	107.6	96.1	83.0	76.7	72.3	68.5	67.9	67.9	68.8
2800 ( 14 hrs)	201.3	145.2	110.1	98.2	84.7	78.2	73.6	69.7	68.7	67.5	67.5
3200 ( 16 hrs)	206.6	148.8	112.7	100.4	86.4	79.7	74.9	70.9	69.8	68.1	67.4
3600 ( 18 hrs)	211.9	152.4	115.2	102.6	88.1	81.1	76.3	72.0	70.8	69.1	68.0
4000 ( 20 hrs)	217.2	156.0	117.8	104.7	89.9	82.6	77.6	73.2	71.9	70.0	68.9
4400 ( 22 hrs)	222.5	159.7	120.3	106.9	91.6	84.1	78.9	74.3	72.9	71.0	69.8
4800 ( 24 hrs)	227.8	163.3	122.8	109.0	93.3	85.6	80.2	75.5	74.0	72.0	70.7


Baseline selected from lowest LCOE at minimum CapEx



## Results: multi-level energy storage

**Problem:** Develop a system design that generates more than the baseline with guaranteed dispatch

- Dynamic electricity pricing model: every day prices can be modified by solar availability, **365 separate cases** possible
- Assumption: At least **6 hours of off-peak** (low-cost) electricity is available every day (likely nights) irrespective of weather
- **10 hours of “guaranteed” generation** under all conditions every day, targeting the highest price hours
- Assumes a **continuous demand for H<sub>2</sub>** in the market
- H<sub>2</sub> Price: \$60/MWh (\$2/kg, based on 120 MJ/kg LHV)
- Does not include revenues from sales of O<sub>2</sub> or capacity payments or other







# Results: multi-level energy storage

L1, L2, and L3 systems under study

Case No	L1 MWh (Hours)	SM	L2 MWh (Hours)	RR MW	L3 MWh (Hours)	eTCH <sub>2</sub> MW	Weather
Only L1	1	2.25					Normal
	2	2.25					Modified
L1-L2	3	2.25	2200 (10)	367			Normal
	4	2.25	2200 (10)	367			Modified
L1-L2-L3	5	2.25	2200 (10)	200	2400 (10)	300	Normal
	6	2.25	2200 (10)	200	2400 (10)	300	Modified

TMY Daggett CA

Data "modified" by adding 1 week of low insolation (avg. 2 hours of sun/per day) to all months

Only L1

L1-L2

L1-L2-L3

Level 1, 2 and 3 with similar storage capacity

L1-to-electricity: 50%  
L2-to-electricity: 45.5%  
L3-to-electricity: 41.7%




# Results: multi-level energy storage L1-L2 system

- Generation went up with addition of Level 2 because generation gaps in low insolation periods are filled
- The revenue does not compensate the higher investment cost and operating cost of off-peak electricity

Case No	Annualized Plant Cost \$M	Off-peak Electricity Cost \$M	Hydrogen Revenue \$M	LCOE \$/MWh	Annual Generation % Capacity	Electricity Revenue \$M	Net Earnings \$M
1	33.00	0.00		67.83	0.56	48.30	15.30
2	33.00	0.00		79.67	0.47	42.20	9.20
3	36.50	4.22		77.60	0.61	53.90	13.18
4	36.50	8.92		90.40	0.58	55.10	9.68
5	39.90	46.90	56.90	55.91	0.61	53.90	24.00
6	39.90	49.40	54.00	69.10	0.58	55.10	19.80

LCOE 15% more than baseline






# Results: multi-level energy storage

L1-L2 system

Capital expenses distribution



Solar plant and power block make up 80% of the total investment costs






# Results: multi-level energy storage L1-L2-L3 system

- Generation w.r.t. L1-L2 system did not increase significantly because not many additional “profitable” generation hours
- The revenues from the H<sub>2</sub> sell compensates for the higher CapEx and OpEx

LCOE 16% less than baseline

Case No	Annualized Plant Cost \$M	Off-peak Electricity Cost \$M	Hydrogen Revenue \$M	LCOE \$/MWh	Annual Generation % Capacity	Electricity Revenue \$M	Net Earnings \$M
1	33.00	0.00		67.83	0.56	48.30	15.30
2	33.00	0.00		79.67	0.47	42.20	9.20
3	36.50	4.22		77.60	0.61	53.90	13.18
4	36.50	8.92		90.40	0.58	55.10	9.68
5	39.90	46.90	56.90	55.91	0.61	53.90	24.00
6	39.90	49.40	54.00	69.10	0.58	55.10	19.80






# Results: multi-level energy storage L1-L2-L3 system

- Generation w.r.t. L1-L2 system did not increase significantly because not many additional “profitable” generation hours
- The revenues from the H<sub>2</sub> sell compensates for the higher CapEx and OpEx

LCOE 16% less than baseline


Case No	Annualized Plant Cost \$M	Off-peak Electricity Cost \$M	Hydrogen Revenue \$M	LCOE \$/MWh	Annual Generation % Capacity	Electricity Revenue \$M	Net Earnings \$M
1	33.00	0.00		67.83	0.56	48.30	15.30
2	33.00	0.00		79.67	0.47	42.20	9.20
3	36.50	4.22		77.60	0.61	53.90	13.18
4	36.50	8.92		90.40	0.58	55.10	9.68
5	39.90	46.90	56.90	55.91	0.61	53.90	24.00
6	39.90	49.40	54.00	69.10	0.58	55.10	19.80





# Results: multi-level energy storage L1-L2-L3 system

Capital expenses distribution



Solar plant and power block make up 74% of the total investment costs





# Summary

- Three receiver configuration with 90-degree difference between each other exhibits the lowest LCOH
- L1-L2 LCOE is 15% above the baseline LCOE, but has a “guaranteed” dispatchable generation
- L1-L2-L3 LCOE is 16% less than baseline LCOE due to H<sub>2</sub> revenue
- To make this system profitable we need low off-peak electricity rates for filling storage or H<sub>2</sub> generation



# Thank you for your attention!!

We would like to acknowledge the team and institutions involved in this work



**SOLAR ENERGY  
TECHNOLOGIES OFFICE**  
U.S. Department Of Energy



Sandia  
National  
Laboratories



**SIEMENS**



**PennState**

This material is based on work supported by the U.S. Department of Energy Solar Energy Technologies Office under Award No. DE-EE0008991. The views expressed herein do not necessarily represent the views of the U.S. Department of Energy or the United States Government.